



Name of Sampler: Lisa Christensen
Date Collected: 06/12/2019
School Name: Ilalko Elementary
School Code: 4417
School District: Auburn
School Address: 301 Oravetz Pl Southeast, Auburn WA 98092
School County: King
Number of Samples Collected: 61
School Point of Contact (POC): Randy Thomas
POC Title: Director of Maintenance and Facilities
POC Email: RThomas@auburn.wednet.edu
POC Phone Number: (253) 931-4955
Date Samples Sent to Lab: 06/12/2019
Date Samples Received by Lab: 07/02/2019
Shipment Tracking Number: NA

| Program ID | Sample Type | Description | Location | Lead Results (ppb) | Analysis Date | Comments |
|------------|-------------|-------------|-------------------------|--------------------|---------------|-------------------------|
| 25297 | other | other | | <1 | 07/08/2019 | 6:49 AM, 06740 |
| 25298 | FirstDraw | Bubbler | Across from Main Office | <1 | 07/08/2019 | |
| 25299 | FirstDraw | Bubbler | Room 123 | <1 | 07/08/2019 | |
| 25300 | FirstDraw | Tap | Room 123 | 2 | 07/08/2019 | |
| 25301 | FirstDraw | Tap | Kitchen, Food Prep Sink | <1 | 07/08/2019 | Back sink, tap dripping |
| 25302 | FirstDraw | other | Kitchen, Food Prep Sink | <1 | 07/08/2019 | Back sink |
| 25303 | FirstDraw | Bubbler | Room 201 | <1 | 07/08/2019 | |
| 25304 | FirstDraw | Tap | Room 201 | 1 | 07/08/2019 | |
| 25305 | FirstDraw | Bubbler | Room 203 | <1 | 07/08/2019 | |
| 25306 | FirstDraw | Tap | Room 203 | 1 | 07/08/2019 | |
| 25307 | FirstDraw | Bubbler | Room 205 | <1 | 07/08/2019 | |
| 25308 | FirstDraw | Tap | Room 205 | <1 | 07/08/2019 | No Aerator |
| 25309 | FirstDraw | Bubbler | Room 207 | <1 | 07/08/2019 | |
| 25310 | FirstDraw | Tap | Room 207 | <1 | 07/08/2019 | |
| 25311 | FirstDraw | Bubbler | Room 206 | <1 | 07/09/2019 | No Aerator |

(continued)

| Program ID | Sample Type | Description | Location | Lead Results (ppb) | Analysis Date | Comments |
|------------|-------------|-------------|----------|--------------------|---------------|-------------------------------------|
| 25312 | FirstDraw | Tap | Room 206 | <1 | 07/09/2019 | Some mineral deposits and corrosion |
| 25313 | FirstDraw | Bubbler | Room 204 | <1 | 07/09/2019 | |
| 25314 | FirstDraw | Tap | Room 204 | 1 | 07/09/2019 | |
| 25315 | FirstDraw | Bubbler | Room 202 | <1 | 07/09/2019 | |
| 25316 | FirstDraw | Tap | Room 202 | <1 | 07/09/2019 | Used this morning |
| 25317 | FirstDraw | Bubbler | Room 302 | <1 | 07/09/2019 | Mineral deposits on bubbler |
| 25318 | FirstDraw | Tap | Room 302 | 2 | 07/09/2019 | |
| 25320 | FirstDraw | Bubbler | Room 304 | <1 | 07/09/2019 | |
| 25321 | FirstDraw | Tap | Room 304 | 1 | 07/08/2019 | |
| 25322 | FirstDraw | Bubbler | Room 306 | <1 | 07/08/2019 | |
| 25323 | FirstDraw | Tap | Room 306 | 1 | 07/08/2019 | |
| 25324 | FirstDraw | Bubbler | Room 311 | 1 | 07/08/2019 | Some mineral deposits on bubbler |
| 25325 | FirstDraw | Tap | Room 311 | 9 | 07/08/2019 | |
| 25326 | FirstDraw | Bubbler | Room 310 | <1 | 07/08/2019 | Some mineral deposits on bubbler |
| 25327 | FirstDraw | Tap | Room 310 | <1 | 07/08/2019 | |
| 25328 | FirstDraw | Bubbler | Room 307 | <1 | 07/08/2019 | |
| 25329 | FirstDraw | Tap | Room 307 | 1 | 07/08/2019 | |
| 25330 | FirstDraw | Bubbler | Room 305 | <1 | 07/08/2019 | Some mineral deposits on bubbler |
| 25331 | FirstDraw | Tap | Room 305 | 2 | 07/08/2019 | |
| 25332 | FirstDraw | Bubbler | Room 303 | 1 | 07/08/2019 | |
| 25333 | FirstDraw | Tap | Room 303 | 2 | 07/08/2019 | |

(continued)

| Program ID | Sample Type | Description | Location | Lead Results (ppb) | Analysis Date | Comments |
|------------|-------------|-------------|-------------|--------------------|---------------|---|
| 25334 | FirstDraw | Bubbler | Room 402 | <1 | 07/08/2019 | Mineral deposits on bubbler |
| 25335 | FirstDraw | Tap | Room 402 | 2 | 07/08/2019 | |
| 25336 | FirstDraw | Bubbler | Room 404 | <1 | 07/09/2019 | Corrosion on bubbler |
| 25337 | FirstDraw | Tap | Room 404 | 2 | 07/09/2019 | |
| 25338 | FirstDraw | Bubbler | Room 406 | <1 | 07/09/2019 | Some mineral deposits on bubbler |
| 25339 | FirstDraw | Tap | Room 406 | 1 | 07/09/2019 | |
| 25340 | FirstDraw | Bubbler | Room 410 | <1 | 07/09/2019 | Mineral deposits on bubbler |
| 25341 | FirstDraw | Tap | Room 410 | 2 | 07/09/2019 | |
| 25342 | FirstDraw | Bubbler | Room 409 | <1 | 07/09/2019 | Small amount of mineral deposits on bubbler |
| 25343 | FirstDraw | Tap | Room 409 | <1 | 07/08/2019 | No Aerator, Tap Drips |
| 25344 | FirstDraw | Bubbler | Room 405 | 1 | 07/08/2019 | Some mineral deposits on bubbler |
| 25345 | FirstDraw | Tap | Room 405 | 2 | 07/08/2019 | |
| 25346 | FirstDraw | Bubbler | Room 403 | <1 | 07/08/2019 | Mineral deposits on bubbler |
| 25347 | FirstDraw | Tap | Room 403 | 2 | 07/08/2019 | |
| 25348 | FirstDraw | Bubbler | Room 401 | <1 | 07/08/2019 | Mineral deposits on bubbler near spout |
| 25349 | FirstDraw | Tap | Room 401 | 5 | 07/08/2019 | |
| 25350 | FirstDraw | Tap | Health Room | <1 | 07/08/2019 | |
| 25350 | FirstDraw | Tap | Health Room | 1 | 07/08/2019 | |

(continued)

| Program ID | Sample Type | Description | Location | Lead Results (ppb) | Analysis Date | Comments |
|------------|-------------|-------------|------------------------------|--------------------|---------------|----------------------------------|
| 25351 | FirstDraw | Bubbler | Room 106 | TB | NA | Some mineral deposits on bubbler |
| 25352 | FirstDraw | Tap | Room 106 | <1 | 07/08/2019 | |
| 25353 | FirstDraw | Bubbler | Room 107 | 1 | 07/08/2019 | |
| 25354 | FirstDraw | Tap | Room 107 | <1 | 07/08/2019 | |
| 25355 | FirstDraw | Tap | Library Workroom , Room 130A | 6 | 07/08/2019 | Used this morning |
| 25356 | FirstDraw | other | Portable 904 | <1 | 07/08/2019 | 604 Classroom |
| 25357 | FirstDraw | other | Portable 903 | <1 | 07/08/2019 | 903 Classroom |
| 25358 | FirstDraw | other | Portable 411 | <1 | 07/08/2019 | |