



**Name of Sampler:** Lisa Christensen  
**Date Collected:** 06/13/2019  
**School Name:** Lake View Elementary  
**School Code:** 4120  
**School District:** Auburn  
**School Address:** 16401 Southeast 318th Street, Auburn WA 98092  
**School County:** King  
**Number of Samples Collected:** 64  
**School Point of Contact (POC):** Randy Thomas  
**POC Title:** Director of Maintenance and Facilities  
**POC Email:** RThomas@auburn.wednet.edu  
**POC Phone Number:** (253) 931-4955  
**Date Samples Sent to Lab:** 06/13/2019  
**Date Samples Received by Lab:** 07/05/2019  
**Shipment Tracking Number:** 787867940516, 787867940527

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25319	other	other		<1	07/09/2019	06628, 6:46 AM
25359	FirstDraw	Tap	Nurses Room (Room 102)	4	07/09/2019	
25360	FirstDraw	Tap	Kitchen, Food Prep Area	6	07/09/2019	Island Sink
25361	FirstDraw	other	Kitchen, Food Prep Area	2	07/09/2019	Island Sink
25362	FirstDraw	Tap	Kitchen, Back 3-compartment sink	3	07/09/2019	Left tap, Culligan filter
25363	FirstDraw	Tap	Kitchen, Back 3-compartment sink	4	07/09/2019	Right Tap
25364	FirstDraw	PotFiller	Kitchen	3	07/09/2019	Back corner of kitchen

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25365	FirstDraw	Bubbler	100 Mall	9	07/09/2019	Left Bubbler, Near Kitchen
25366	FirstDraw	Bubbler	100 Mall	4	07/09/2019	Right Bubbler, Near Kitchen
25367	FirstDraw	Bubbler	100 Mall	17	07/09/2019	Near Main Office, Left Bubbler
25368	FirstDraw	Bubbler	100 Mall	8	07/09/2019	Near Main Office, Right Bubbler
25369	FirstDraw	Bubbler	Room 105	17	07/09/2019	
25370	FirstDraw	Tap	Room 105	8	07/09/2019	
25371	FirstDraw	Bubbler	Room 106	8	07/09/2019	
25372	FirstDraw	Tap	Room 106	8	07/09/2019	
25373	FirstDraw	Bubbler	Outside Gym	7	07/09/2019	
25374	FirstDraw	Bubbler	Room 303	15	07/09/2019	
25375	FirstDraw	Tap	Room 303	12	07/09/2019	
25376	FirstDraw	Bubbler	Room 305	6	07/09/2019	Mineral deposits on bubbler mouth
25377	FirstDraw	Tap	Room 305	7	07/09/2019	
25378	FirstDraw	Bubbler	Room 306	17	07/09/2019	
25379	FirstDraw	Tap	Room 306	9	07/09/2019	
25380	FirstDraw	Bubbler	East Hall Bubblers (Near Room 306)	5	07/09/2019	Left Bubbler
25381	FirstDraw	Bubbler	East Hall Bubblers (Near Room 306)	5	07/09/2019	Right Bubbler

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25382	FirstDraw	Bubbler	Room 312	11	07/09/2019	Some mineral deposits on bubbler
25383	FirstDraw	Tap	Room 312	8	07/09/2019	
25384	FirstDraw	Bubbler	Room 313	15	07/09/2019	Mineral deposits on bubbler
25385	FirstDraw	Tap	Room 313	10	07/09/2019	
25386	FirstDraw	Bubbler	Room 314	11	07/09/2019	
25387	FirstDraw	Tap	Room 314	2	07/09/2019	
25388	FirstDraw	Bubbler	East Hall Near Staff Lounge	15	07/09/2019	
25389	FirstDraw	Bubbler	Room 401	10	07/09/2019	
25390	FirstDraw	Tap	Room 401	4	07/09/2019	
25391	FirstDraw	Bubbler	Room 403	8	07/09/2019	Mineral deposits on bubbler
25392	FirstDraw	Tap	Room 403	4	07/09/2019	
25393	FirstDraw	Bubbler	Room 404	9	07/09/2019	Mineral deposits on bubbler
25394	FirstDraw	Tap	Room 404	3	07/09/2019	
25395	FirstDraw	Bubbler	Room 405	6	07/09/2019	
25396	FirstDraw	Tap	Room 405	1	07/09/2019	
25397	FirstDraw	Bubbler	Room 406	8	07/09/2019	
25398	FirstDraw	Tap	Room 406	4	07/09/2019	
25399	FirstDraw	Bubbler	Room 408	7	07/09/2019	
25400	FirstDraw	Tap	Room 408	4	07/09/2019	
25401	FirstDraw	Bubbler	Room 212	17	07/09/2019	Mineral deposits on bubbler
25402	FirstDraw	Tap	Room 212	13	07/09/2019	
25403	FirstDraw	Bubbler	Room 211	10	07/09/2019	Some mineral deposits on bubbler
25404	FirstDraw	Tap	Room 211	7	07/09/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25405	FirstDraw	Bubbler	Room 210	7	07/09/2019	
25406	FirstDraw	Tap	Room 210	7	07/09/2019	
25407	FirstDraw	Bubbler	West Hall Near Room 207 (Near Bath- rooms)	3	07/09/2019	Left Bubbler
25408	FirstDraw	Bubbler	West Hall Near Room 207 (Near Bath- rooms)	2	07/09/2019	Right Bubbler
25409	FirstDraw	Bubbler	Room 205	10	07/09/2019	
25410	FirstDraw	Tap	Room 205	8	07/09/2019	
25411	FirstDraw	Bubbler	Room 204	5	07/09/2019	Mineral deposits on bubbler
25412	FirstDraw	Tap	Room 204	11	07/09/2019	
25413	FirstDraw	Bubbler	Room 202	5	07/09/2019	Bubbler head is loose
25414	FirstDraw	Tap	Room 202	14	07/09/2019	
25415	FirstDraw	Bubbler	Room 201	<1	07/09/2019	
25416	FirstDraw	Tap	Room 201	1	07/09/2019	
25417	FirstDraw	Bubbler	Room 301	1	07/09/2019	Mineral deposits in bubbler spout
25418	FirstDraw	Tap	Room 301	<1	07/09/2019	
25419	FirstDraw	Bubbler	Room 302	18	07/09/2019	Mineral deposits on bubbler
25420	FirstDraw	Tap	Room 302	9	07/09/2019	
25421	FirstDraw	Tap	Library Workroom	16	07/09/2019	