



**Name of Sampler:** Lisa Christensen  
**Date Collected:** 06/14/2019  
**School Name:** Lakeland Hills Elementary  
**School Code:** 5051  
**School District:** Auburn  
**School Address:** 1020 Evergreen Way Southeast, Auburn WA 98092  
**School County:** King  
**Number of Samples Collected:** 69  
**School Point of Contact (POC):** Randy Thomas  
**POC Title:** Director of Maintenance and Facilities  
**POC Email:** RThomas@auburn.wednet.edu  
**POC Phone Number:** (253) 931-4955  
**Date Samples Sent to Lab:** 06/14/2019  
**Date Samples Received by Lab:** 07/08/2019  
**Shipment Tracking Number:** NA

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25422	other	other		<1	07/15/2019	06617, 6:42 AM
25423	FirstDraw	Tap	Kitchen, Food Prep Area	2	07/15/2019	
25424	FirstDraw	Tap	Room 101 (Health Room)	1	07/15/2019	Some mineral deposits in aerator
25425	FirstDraw	Tap	Room 107	<1	07/15/2019	Left Sink, Bubbler on sink turned off
25426	FirstDraw	Bubbler	Room 107	<1	07/15/2019	Right Sink
25427	FirstDraw	Tap	Room 107	<1	07/15/2019	Right Sink
25428	FirstDraw	Bubbler	Room 106	1	07/15/2019	Some mineral deposits on bubbler, Left Sink
25429	FirstDraw	Tap	Room 106	<1	07/15/2019	Left Sink
25430	FirstDraw	Bubbler	Room 106	3	07/15/2019	Right Sink
25431	FirstDraw	Tap	Room 106	<1	07/15/2019	Right Sink

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25432	FirstDraw	Bubbler	Room 110	<1	07/15/2019	Mineral deposits on bubbler
25433	FirstDraw	Tap	Room 110	<1	07/15/2019	
25434	FirstDraw	Bubbler	Next to Main Office	<1	07/15/2019	Left
25435	FirstDraw	Bubbler	Next to Main Office	1	07/15/2019	Right
25436	FirstDraw	Bubbler	Room 111	1	07/15/2019	
25437	FirstDraw	Tap	Room 111	1	07/15/2019	
25438	FirstDraw	Tap	Staff Lounge	<1	07/15/2019	
25439	FirstDraw	Bubbler	Room 200	1	07/15/2019	Mineral deposits on bubbler
25440	FirstDraw	Tap	Room 200	<1	07/15/2019	Some rust on aerator
25441	FirstDraw	Bubbler	Room 202	2	07/15/2019	
25442	FirstDraw	Tap	Room 202	1	07/15/2019	
25443	FirstDraw	Bubbler	Room 204	1	07/15/2019	Some mineral deposits on bubbler
25444	FirstDraw	Tap	Room 204	1	07/15/2019	
25445	FirstDraw	Bubbler	Room 206	1	07/15/2019	Some mineral deposits on bubbler
25446	FirstDraw	Tap	Room 206	<1	07/15/2019	
25447	FirstDraw	Bubbler	Room 208	2	07/15/2019	Some mineral deposits on bubbler
25448	FirstDraw	Tap	Room 208	<1	07/15/2019	
25449	FirstDraw	Bubbler	Room 207	<1	07/15/2019	Some mineral deposits on bubbler
25450	FirstDraw	Tap	Room 207	<1	07/15/2019	
25451	FirstDraw	Bubbler	Room 205	1	07/15/2019	
25452	FirstDraw	Tap	Room 205	<1	07/15/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25453	FirstDraw	Bubbler	Room 203	<1	07/15/2019	
25454	FirstDraw	Tap	Room 203	<1	07/15/2019	
25455	FirstDraw	Bubbler	Room 201	1	07/15/2019	
25456	FirstDraw	Tap	Room 201	1	07/15/2019	
25457	FirstDraw	Tap	Library Office	<1	07/15/2019	No Aerator
25458	FirstDraw	Bubbler	Room 303	<1	07/15/2019	Some mineral deposits on bubbler
25459	FirstDraw	Tap	Room 303	<1	07/15/2019	
25460	FirstDraw	Bubbler	Room 305	<1	07/15/2019	
25461	FirstDraw	Tap	Room 305	<1	07/15/2019	
25462	FirstDraw	Bubbler	Room 309	<1	07/15/2019	Some mineral deposits on bubbler
25463	FirstDraw	Tap	Room 309	<1	07/15/2019	
25464	FirstDraw	Bubbler	Room 310	<1	07/15/2019	Mineral deposits on bubbler
25465	FirstDraw	Tap	Room 310	<1	07/15/2019	
25466	FirstDraw	Bubbler	Room 306	<1	07/15/2019	Some green slime on bubbler
25467	FirstDraw	Tap	Room 306	<1	07/15/2019	Mineral deposits in aerator
25468	FirstDraw	Bubbler	Room 304	<1	07/15/2019	Some dark slime on bubbler
25469	FirstDraw	Tap	Room 304	1	07/15/2019	
25470	FirstDraw	Bubbler	Room 302	<1	07/15/2019	
25471	FirstDraw	Tap	Room 302	2	07/15/2019	Some rust on aerator
25472	FirstDraw	Bubbler	Room 301, Workroom	6	07/15/2019	Mineral deposits on bubbler
25473	FirstDraw	Tap	Room 301, Workroom	<1	07/15/2019	No Aerator

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
25474	FirstDraw	Bubbler	Cafe Area	<1	07/15/2019	Left
25475	FirstDraw	Bubbler	Cafe Area	<1	07/15/2019	Right
25476	FirstDraw	Bubbler	Room 401	1	07/15/2019	
25477	FirstDraw	Tap	Room 401	2	07/15/2019	
25478	FirstDraw	Bubbler	Room 403	<1	07/15/2019	Some mineral deposits on bubbler
25479	FirstDraw	Tap	Room 403	1	07/15/2019	
25480	FirstDraw	Bubbler	Room 407	1	07/15/2019	Some mineral deposits on bubbler
25481	FirstDraw	Tap	Room 407	1	07/15/2019	
25482	FirstDraw	Bubbler	Room 408	<1	07/15/2019	Some mineral deposits on bubbler
25483	FirstDraw	Tap	Room 408	3	07/15/2019	
25484	FirstDraw	Bubbler	Room 404	<1	07/15/2019	
25485	FirstDraw	Tap	Room 404	2	07/15/2019	
25486	FirstDraw	Bubbler	Room 402	<1	07/15/2019	Mineral deposits on bubbler
25487	FirstDraw	Tap	Room 402	1	07/15/2019	
25488	FirstDraw	Bubbler	Room 400	3	07/15/2019	
25489	FirstDraw	Tap	Room 400	7	07/15/2019	
25490	FirstDraw	Tap	Main Office	<1	07/15/2019	Used this morning